



Certificate of Compliance

This certificate is issued for the following:

FIREMIKS®
Foam Concentrate Proportioner Systems
(See Attached Listing)

Prepared for:
Firemiks AB
P.O. Box 8155
Stockholm, SE-104 20
Sweden

FM Approvals Class: 5130
FM Approval Standard: Class Series 5130 (Dec. 2014)

Approval Identification: 3060416
Revision Request: RR221781

Approval Granted: January 9, 2018
Approved: January 16, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller", is written over a horizontal line.

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Foam Concentrate Proportioners

<i>Proportioner Model</i>	<i>Minimum Flow Rate, gal/min (Lpm)</i>	<i>Maximum Flow Rate, gal/min (Lpm)</i>	<i>Nominal Water Line Size, in. (mm)</i>	<i>Nominal Proportioning Ratio</i>
450-3-PP-F-ALU-FM 450-3-PP-F-BRZ-FM 450-3-PP-F-SS-FM	30 (112)	119 (450)	2 (50)	3%
800-3-PP-F-ALU-FM 800-3-PP-F-BRZ-FM 800-3-PP-F-SS-FM	36 (135)	211 (800)	2.5 (65)	3%
1200-3-PP-F-ALU-FM 1200-3-PP-F-BRZ-FM 1200-3-PP-F-SS-FM	69 (260)	317 (1200)	3 (80)	3%
1800-3-PP-F-ALU-FM 1800-3-PP-F-BRZ-FM 1800-3-PP-F-SS-FM 1800-3-PP-F-ALU-SS-FM 1800-3-PP-F-BRZ-SS-FM 1800-3-PP-F-SS-SS-FM	63 (240)	476 (1800)	4 (100)	3%
2400-3-PP-F-ALU-FM 2400-3-PP-F-BRZ-FM 2400-3-PP-F-SS-FM	82 (311)	634 (2400)	4 (100)	3%
3200-3-PP-F-ALU-FM 3200-3-PP-F-BRZ-FM 3200-3-PP-F-SS-FM	132 (500)	845 (3200)	5 (125)	3%



Member of the FM Global Group