



# Certificate of Compliance

This certificate is issued for the following:

**FIREMIKS®**  
**Foam Concentrate Proportioner Systems**  
(See Attached Listing)

**Prepared for:**  
Firemiks AB  
P.O. Box 8155  
Stockholm, SE-104 20  
Sweden

FM Approvals Class: 5130  
FM Approval Standard: Class Series 5130 (Dec. 2014)

Approval Identification: 3060416  
Revision Request: RR221781

Approval Granted: January 9, 2018  
Approved: January 16, 2020

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David Fuller  
VP - Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*



# Certificate of Compliance

## Foam Concentrate Proportioners

<i>Proportioner Model</i>	<i>Minimum Flow Rate, gal/min (Lpm)</i>	<i>Maximum Flow Rate, gal/min (Lpm)</i>	<i>Nominal Water Line Size, in. (mm)</i>	<i>Nominal Proportioning Ratio</i>
450-3-PP-F-ALU-FM 450-3-PP-F-BRZ-FM 450-3-PP-F-SS-FM	30 (112)	119 (450)	2 (50)	3%
800-3-PP-F-ALU-FM 800-3-PP-F-BRZ-FM 800-3-PP-F-SS-FM	36 (135)	211 (800)	2.5 (65)	3%
1200-3-PP-F-ALU-FM 1200-3-PP-F-BRZ-FM 1200-3-PP-F-SS-FM	69 (260)	317 (1200)	3 (80)	3%
1800-3-PP-F-ALU-FM 1800-3-PP-F-BRZ-FM 1800-3-PP-F-SS-FM 1800-3-PP-F-ALU-SS-FM 1800-3-PP-F-BRZ-SS-FM 1800-3-PP-F-SS-SS-FM	63 (240)	476 (1800)	4 (100)	3%
2400-3-PP-F-ALU-FM 2400-3-PP-F-BRZ-FM 2400-3-PP-F-SS-FM	82 (311)	634 (2400)	4 (100)	3%
3200-3-PP-F-ALU-FM 3200-3-PP-F-BRZ-FM 3200-3-PP-F-SS-FM	132 (500)	845 (3200)	5 (125)	3%



*Member of the FM Global Group*